

Tender for

**Work of “Supply & Replacement of Spares for
Balance of Plant (BOP) area” at GMDC’s 2x125 MW
Akrimota Thermal Power Station**

Tender No: - GMDC/POWER/ATPS/ 03 /24-25

Answer to Pre-Bid Queries and Corrigendum - V



**Gujarat Mineral Development Corporation Limited
Khanij Bhavan, 132-Ring Road, Gujarat University
Ground, Vastrapur, Ahmedabad- 380052**

Responses to pre-bid queries

Sr. No.	Clause No.	Description	Pre-bid query/ Clarification	Response / Addendum / Corrigendum (If any)
1.	NIL Period of Contract	The period of contract will be 60 days from the date of acceptance of LOI.	<p>1. SI no:1 (750 NB Rubber bellows - OEM- Cori Engineers pvt ltd), Min manufacturing time 3 Months</p> <p>2. SI no:3 (GSF Inlet & Outlet Gate with actuator -OEM- Mecha Tech Ind), Min Manufacturing time 4 Months</p> <p>Supply items manufacturing time itself takes 3 to 4 months and after receipt of materials at site we need replacement time of 1 month minimum.</p> <p>Kindly look into the above matter and extend the above-mentioned items supply and replacement time up to 5 months minimum to execute the work</p>	Modified Clause: The period of contract will be 16 weeks from the date of acceptance of LOI.
2.	NIL Period of Contract	The period of contract will be 60 days from the date of acceptance of LOI.	We can provide the best delivery of 3 ½ months for the revised scope of work. However, we request you to provide an extra grace period of 15 days for LD/Penalty applicability.	As per response provided in S. No. 1 above.
3.	S. No. 15 of Corrigendum 2	<p>(1) In case of GSF inlet & outlet gate (07+07=14 nos) with foundation frame, bidder has to supply complete assembly of one sample of each gate along with drawing for approval to GMDC, and after getting approval, shall supply balance quantity.</p> <p>(2) For ascertaining MOC of sample material bidder has to make assessment at site.</p> <p>(3) As clarified in (1) above.</p>	Your present tender requirement of 14 Nos. CI Sluice Gates for GSF inlet & outlet is also for same application i.e. for SWTP, hence, there is no necessity of providing sample for Gates. Please confirm.	Gsf Inlet gate (450x450 mm) & outlet gate (500 x 500 mm) are of different sizes and to be installed at different location with required civil work as compared to 850mm x1200 mm & 1100 mm x 900 mm sluice gates. So bidder has to supply complete assembly of one sample of each gate

Sr. No.	Clause No.	Description	Pre-bid query/ Clarification	Response / Addendum / Corrigendum (If any)
				along with drawing for approval to GMDC, and after getting approval, shall supply balance quantity.
4.	S. No. 16 of Corrigendum 2	For the smooth execution of work at site without any delay from civil related work, Bidder has to make necessary arrangements to carry out civil related work by themselves or by another agency under bidder's supervision, responsibility & cost as per standard practice and IS Codes, with no additional cost/time implication on GMDC. (For example, Civil work required in case of, including but not limited to, GSF inlet & outlet gate replacement work.)	<p>Bidder shall carry out only minor civil works pertaining to chipping and grouting works if required.</p> <p>However, all other civil works like Civil design, excavation, digging, embedment's, first stage and second stage concreting, piling, slabs, rafts, columns, foundation work, shim plates, foundation bolts etc., is excluded from our scope of work as it is not our area of expertise. The required work may be suitably carried out by GMDC/Other agency.</p>	Successful Bidder has to carry out or make necessary arrangements (at his own cost) for all required civil work including excavation, digging, embedments, first stage and second stage concreting, piling, slabs, rafts, columns, foundation work, shim plates, foundation bolts etc. for fast & easy execution of the work at site without any delay from civil related work
5.	S. No. 24 of Corrigendum 2	Modified Clause: Quantity of supply items may increase or decrease as per requirement of ATPS. GMDC reserves the right to remove any line item from the BOQ or decrease the quantity of supply and replacement of any items in the BOQ, as required (to be read along with Clause 24.3 of the tender). In case quantity to be supplied is increased, variation should not be more than 20% of total contract value.	Bidder wishes to inform that in case quantity to be supplied as per scope of work mentioned in "Annexure-I: Revised BOQ" is increased, then price variation up to 20% of total contract value as stated in the Response column will be executed by the Bidder at an additional cost.	<p>Modified Clause:</p> <p>Quantity of supply items may increase or decrease as per requirement of ATPS. GMDC reserves the right to remove any line item from the BOQ or decrease the quantity of supply and replacement of any items in the BOQ, as required (to be read along with Clause 24.3 of the tender). In case</p>

Sr. No.	Clause No.	Description	Pre-bid query/ Clarification	Response / Addendum / Corrigendum (If any)
				quantity to be supplied is increased, variation should not be more than 20% of total contract value (including charges for both supply and replacement), which shall be executed by bidder at additional cost to GMDC, as per same terms & conditions of the original contract.
6.	S.no. 2 of Corrigendum 2 Annexure-I: Revised BOQ	CW system CW system: Service charges of replacement of CT fills & Drift eliminator of cooling tower	Bidder wishes to inform GMDC that the following activities are not considered in Bidder's scope: - Any work related to dismantling/removal of existing PVC fills and Drift Eliminators and storing the removed materials in the designated area in seven (7) nos. Cells of Cooling Tower. The same to be suitably arranged by GMDC. - Any kind of Sludge cleaning, algae removal, slush cleaning, mud removal, dewatering work and desilting work inside the seven (7) nos. Cells of Cooling Tower. The same to be suitably arranged by GMDC.	All activities required for end-to-end replacement of existing CT fills and Drift eliminators of Cooling Tower with new PVC fills material and new drift eliminators shall be in the Successful Bidder's scope. These activities include but not limited to removal of all broken fills from inside the CT basin & outside surrounding area and shifting to the designated area for storage of scrap materials from seven (7) nos. cells of Cooling Tower. Also, any kind of sludge cleaning, algae removal, slush cleaning, mud removal, dewatering work desilting work inside the seven (7) nos. cells of

Sr. No.	Clause No.	Description	Pre-bid query/ Clarification	Response / Addendum / Corrigendum (If any)
				Cooling Tower & any other hinderance removal activities required for successfully executing the work are also in scope of Successful Bidder.
7.	Price Bid Form			Bidder shall quote charges for supply of items and service charges for replacement of items separately. Updated price bid format is attached in Annexure-I of this corrigendum. The contract will be awarded to the bidder who stands L1 in total price (including charges for both supply and replacement). (Price Bid on the n-procure portal has been updated accordingly)
8.	S. No. 27 of Corrigendum 2	Modified Clause 18.4: An ad -hoc payment @ 80% of the payable amount arrived after considering above deduction (as mentioned in Clause 18.3 of the tender), will be paid by office of the Head (PP & A), within 30 days of submission of the invoice along with its details. The invoice shall then be sent to GMDC's Corporate Office at Ahmedabad for verification, auditing and approval. Balance 20% payable	Query A. Bidder wishes to inform GMDC that Items mentioned in S.no. 1 and S. no. 3 of "Annexure -I: Revised BOQ " have both Supply and Service components. For these items, we are suggesting the following payment terms: (i). 80% + 100% GST against Material Receipt Certificate at site on pro-rata basis. (ii). 20% after completion of services on pro-rata basis. Query B. Bidder wishes to inform that Item mentioned in S.no. 2 of "Annexure-I: Revised	Response to queries A. and B. Modified Clause 18.1: Successful bidder shall submit bill for items which have been supplied or replaced, within 7 days.

Sr. No.	Clause No.	Description	Pre-bid query/ Clarification	Response / Addendum / Corrigendum (If any)
		<p>amount of Running account invoices shall become payable by Project within two weeks of the receipt of the approved invoice from Corporate Office. Owner shall be entitled to withhold payment if any of the invoices do not include the supporting documents required by the Owner (if any) and shall only be released after getting proper supporting documents, including statutory payments, from the Successful Bidder. No interest shall be paid by the Owner on any delayed/ disputed payments.</p>	<p>BOQ ” is related to Service component only. For this item, we propose the following payment terms:</p> <p>(i) 100% against RA bills on pro -rata basis after certification of RA Bills from site.</p> <p>Query C. Also, for S.no. 3 Item, Bidder can carry out his services only after receipt of new PVC fills and Drift Eliminators at ATPS Site as the defined scope of work by bidder in “Annexure-I: Revised BOQ ” is pertaining to replacement of new PVC fills and Drift Eliminators only. Since the supply of new PVC fills and Drift Eliminators is not in Bidder’s scope, the timeline for commencement and completion of the replacement of new PVC fills and Drift Eliminators cannot be calculated and fixed by the bidder at this stage as bidder is dependent on GMDC/Other agency for Supply. Therefore, Bidder urges GMDC to keep a cap on the Service completion timeline. If the supplies are not received within the prescribed capped time-frame then the awarded Purchase order should be short closed at that point in time. Please confirm.</p> <p>Query D. Further, we shall provide diminished/reduced value SDBG equivalent to value of S.No. 3 Item, “Annexure -I: Revised BOQ ” in case we happen to complete the Supply and Services for S.no. 1 and S.no. 3 items of “Annexure-I: Revised BOQ ” upfront and within the agreed contract timelines. Please confirm</p>	<p>18.1.1. For payment of supply of items, Successful Bidder shall submit bills for</p> <p>(i) 70% of supply charges for items, on pro-rata basis, after material delivery and inspection at site, against Material Receipt Certificate and other necessary documents as required.</p> <p>(ii) Remaining 30% of supply charges for items, on pro-rata basis, after completion of all required services pertaining to the items, as per the scope.</p> <p>18.1.2. For payment of replacement of items, Successful Bidder shall submit bills for</p> <p>(i) 100% of service charges for replacement of items, on pro-rata basis, after completion of all required services as per the scope and certification of RA Bills from site.</p>

Sr. No.	Clause No.	Description	Pre-bid query/ Clarification	Response / Addendum / Corrigendum (If any)
				<p>Response to query C: For item mentioned in S. No. 2 of "Annexure- I: Revised BOQ" of Corrigendum 2 (CW system: Service charges of replacement of CT fills & Drift eliminator of cooling tower), suitable extension shall be granted to the Successful Bidder for completion of services pertaining to S. No. 2 of the revised BOQ, once it has been established that delay in execution of services is because of delay in supply of new CT fills and drift eliminators from GMDC's end. In case delay in execution of services is because of reasons attributable to the Successful Bidder, no extension will be granted.</p> <p>Response to query D. - As per Tender and responses provided in Corrigendum 2</p>
9.	S. No. 28 of Corrigendum 2	Modified Clause: The Successful bidder shall take adequate statutorily prescribed insurance cover for all men and machinery engaged by him/it for performance of the work at site. Any statutory, legal, financial and other	Bidder shall check with the Insurance agency on the given modified clause no. 25.2 and suitably revert to GMDC with clarifications / observations, if any	As per Tender and responses provided in Corrigendum 2

Sr. No.	Clause No.	Description	Pre-bid query/ Clarification	Response / Addendum / Corrigendum (If any)
		liabilities or insurance claims brought against the GMDC by an individual or by customers or by any such other persons who suffered damage due to negligence of the Successful bidder or his employees, the same shall be settled by the successful bidder at his cost.		
10.	S.no. 2 of Corrigendum 2 Annexure-I: Revised BOQ	<p>S. No. 1 Supply & replacement Complete assembly of 750NB rubber bellow with fasteners (9 Nos)</p> <p>S. No. 3: Supply and replacement of GSF inlet & outlet gate without actuator & with foundation frame (14 Nos)</p>		Successful Bidder's scope for supply and replacement covers all activities required for end-to-end replacement of existing rubber bellows assembly with fasteners kit and existing GSF inlet and outlet gates assembly, with new rubber bellow assembly with fasteners kit and new GSF inlet and outlet gates without actuator and with foundation frame, respectively. The Successful Bidder's scope also includes but is not limited to, any kind of sludge cleaning, algae removal, slush cleaning, mud removal, dewatering work, desilting work, any other hinderance removal activities required for successfully executing the work.

Annexure-I: Updated price bid format

Sr. No.	Component/ Area	Item	Qty (Nos)	Unit Rate (in INR, Excl. GST)	Total Amount (in INR, Excl. GST)
1.1	CW system	Charges for supply of complete assembly of 750NB rubber bellow with fasteners	9		
1.2		Service charges for replacement of Complete assembly of 750NB rubber bellow with fasteners	9		
2		Service charges for replacement of CT fills & Drift eliminator of cooling tower	7		
3.1	SWTP	Charges for supply of GSF inlet & outlet gate without actuator & with foundation frame	14		
3.2		Service charges for replacement of GSF inlet & outlet gate without actuator & with foundation frame	14		
Total Contract Amount (in INR, Exc. GST)					