

The Work of Supply of Lime Stone Powder for 2 X125MW Akrimota Thermal Power Station

Corrigendum-1

Sr no	Clause No	Description of Clause	Prebid query/Clarification	Response/Addendum/Corrigendum (if any)
1	Page no:5	<p>Rs.42000/- (Rupees Forty two thousand only) in Form of</p> <ul style="list-style-type: none"> ➤ DD in favour of GMDC Ltd. Payable at Ahmedabad. ➤ Digital Mode, please note if payment is made through Digital Mode kindly submit the receipt of the same in the attached documents. RTGS details for payment (Annexure-B) <p>ICICIBank, Ahmedabadbranch, Ahemdadbab Account Number: 002405019379 RTGS IFSC: ICICI0000024</p>		<p>Rs.42000/- (Rupees Forty two thousand only) in Form of</p> <ul style="list-style-type: none"> ➤ DD in favour of GMDC Ltd. Payable at ATPS Project, Nani Chher, Ta:Lakhpat,Kutch-370602 ➤ Digital Mode, please note if payment is made through Digital Mode kindly submit the receipt of the same in the attached documents. RTGS details for payment (Annexure-B) <p>Bank of Baroda, Panandhro Branch, Panandhro, Ta.Lakhpat, kutch-370601</p> <p>AccountNumber: 90580400000264 RTGS IFSC:BARB0DBPDRO (FIFTH DIGIT IS ZERO)</p>
2	12.3 (B)	Bidder has to deploy required resources & machineries for lime stone powder feeding at lime day bin at 24 mtr.height at ATPS site as per instruction of Engineer In Charge(EIC) i.e 125 NB flexible hose	We would like to clarify that for unloading/feeding of limestone powder into the Lime Day bin,air pressure of 2.0 to 2.5 kg is required and the arrangements shall be made by us	Bidder has to deploy required resources & machineries for lime stone powder feeding at lime day bin at 24 mtr.height at ATPS site as per instruction of Engineer In Charge(EIC) i.e 125 NB flexible hose pipe, compressor and all fitting for pneumatic conveying from bunker to Lime Day bin at 24 mtr.All necessary arrangement for the same will be done by bidder.

		pipe, compressor and all fitting for pneumatic conveying from bunker to Lime Day bin at 24 mtr.All necessary arrangement for the same will be done by bidder.		However,compressed air supply having pressure of 2.0 to 2.5which is required for feeding of limestone powder into the Day Bin will be provided at single point by GMDC at site.
3.		Clarity regarding Lime powder.		Lime powder in tender shall be read as Lime stone powder.